



BID ADDENDUM NO. 1  
January 12, 2018

## Town of Mansfield, Connecticut Vehicle Exhaust Extraction Systems

**TO: Prospective Bid Proposers:**

This Addendum forms part of the "Request for Proposal – Vehicle Exhaust Extraction Systems" and modifies or clarifies the original "Request for Proposal – Vehicle Exhaust Extraction Systems" for this project dated January 17, 2018. Prospective Bid Proposers shall acknowledge receipt of the addendum and submit with their bid. Failure to do so may subject the Bid Proposers to disqualification.

**Pre-Bid Walkthrough Questions:**

The following are questions that have been received from potential bidders with the following answer provided in bold italics below:

Q1: Station #107 – There are 2 floors there. Top floor with 3 vehicles and bottom with 2 vehicles. Total of 5 vehicles. Please confirm.

**A1: Yes, there are five (5) vehicles.**

Q2: Station #107 – I did not see how there would be access to use one fan for both floors. Please confirm you would be using 2 separate fans for the 2 floors.

**A2: Yes, we want two separate systems.**

Q3: Station #107 – Please confirm power: single or 3 phase power.

**A3: Single phase power.**

Q4: Station #207 – 2 vehicles back in. Please confirm.

**A4: Yes, two (2) vehicles back in.**

Q5: Station #207 – Please confirm power: single or 3 phase power.

**A5: 3 Phase Power**

Q6: Station #307 – Please confirm number of vehicles that you would like to have hook ups for. I believe there would be 6 for front trucks only. Please confirm.

**A6: There are five (5) vehicles and there should be six (6) hook ups as we may add 1 or 2 vehicles in the future.**

Q7: Station #307 – One bay had an antique behind another truck. I assume you would not be doing a drop there but please confirm.

**A7: We will need a drop there.**

Q8: Stations #307 – Also, the ambulance from the hospital... will you be connecting that? Please confirm.

**A8: We want all the ambulances covered, which should happen by covering all of the bays.**



BID ADDENDUM NO. 1  
January 12, 2018

Q9: Station #307 – Please confirm power: single or 3 phase power.

A9: ***Single phase power.***

This addendum must be signed and returned with your Bid.

\_\_\_\_\_  
Authorized Signature of Bidder

\_\_\_\_\_  
Company Name

**End of Addendum No. 1**