



BID ADDENDUM NO. 3
March 26, 2018

Town of Mansfield, Connecticut Roof Replacements at Bicentennial Pond Park and Animal Control Facility

TO: Prospective Bid Proposers:

This Addendum forms part of the "Request for Proposal – Roof Replacements at Bicentennial Pond Park and Animal Control Facility" and modifies or clarifies the original "Request for Proposal – Roof Replacements at Bicentennial Pond Park and Animal Control Facility" for this project dated March 29, 2018. Prospective Bid Proposers shall acknowledge receipt of the addendum and submit with their bid. Failure to do so may subject the Bid Proposers to disqualification.

Scope of Work

On Page 2, under Scope of Work, add the following sentence to Item #12:

All gutter systems shall be separate from the roof.

On Page 2, under Scope of Work, add Item #15 following Item #14:

15. Install zinc strip at the top of all the buildings at the Bicentennial Pond Park location.

On Page 2, under Scope of Work, add Item #16 following Item #15:

16. Install new trim and paint to match in all areas where trim or rotted wood has been removed.

Bid Form

Delete the first sentence in its entirety and insert the following in its place:

The undersigned proposes to furnish all labor, materials, and equipment required for Roof Replacements at Bicentennial Pond Park and Animal Control Facility for the Town of Mansfield in accordance with the accompanying scope of work, for the contract prices specified below.

Insert the following on the Bid Form after the item "Proposed Total Lump Sum Cost all the locations at the Bicentennial Pond Park and all the locations at the Animal Control Building":

Wood Board for Trim.....\$_____ /per linear foot

Questions

Q1: Does the Town require any special fasteners?

A1: The Town does not want to see the fasteners on the roof.

This addendum must be signed and returned with your Bid.

Authorized Signature of Bidder

Company Name

End of Addendum No. 3